



City of Hollister
Office of the Airport Manager

Send All Mail To:
375 Fifth Street • Hollister, CA 95023-3876
Phone: (831) 636-4365 • Fax: (831) 636-4366

Office Location:
90 Skylane Dr. • Suite 101

3/21/08

Response to the RFP meeting questions submitted on 3/18/08.

1. What is the dimension's of the project areas?

Dimensions of the parcels have been placed upon the RFP exhibit A.

2. What is the maximum building height at the Building Restriction Line and also at the parcel edge?

The BRL is by definition the point at which the 7:1 transitional surface (which starts at the lateral edge of the primary surface) reaches a height of 35 feet. In general, it is assumed that a two story building could be sited on the BRL. The height restriction at the edge of the project area should be 3.5 feet. The formula is 1 vertical foot of building height for every 7 feet beginning 250 feet from the center of the runway. This would need to be verified by an exact survey.

3. Where are the Utilities and Storm Drains in the area?

Utilities maps of the area are attached as exhibit B.

4. What is the definition of Taxilane?

The FAA definition for Taxilane as per AC 150/5300-13 is “*Taxilane (TL)*. The portion of the aircraft parking area used for access between taxiways and aircraft parking positions.”

5. Is the general public going to be able to access the project area?

There is no planned and approved general public access to the project area.

6. What is the planned status of the extra row of hangers?

The extra rows of hangers shown in error have been removed from exhibit A.

Thank you,

Mike Chambless
Acting Airport Manager